



STONE CURB

N.T.S.

NOTES:

1. CURB THICKNESS T IS TO BE 5" AND CURB REVEAL 7 1/4" OR AS INDICATED ON THE DRAWINGS.
2. PROVIDE 0" CURB REVEAL FOR HEADER CURB AT SIDEWALK RAMPS AND 1?" FOR HEADER CURB AT DRIVEWAYS.
3. CONCRETE SHALL BE USED FOR STONE CURB REPLACEMENT ONLY.
4. USE CONCRETE WHEN STONE CURB IS BEING REPLACED. TYPICAL PAVEMENT SECTION SHALL BE USED WHEN INSTALLED ON NEW OR RECONSTRUCTED.
5. THE TOP OF THE NEW CLASS C CONCRETE IS TO BE EVEN WITH OR LOWER THAN THE TOP OF THE EXISTING BASE, IN ORDER TO PROVIDE MINIMUM THICKNESS ASPHALT TOP AND BINDER.

JULY 2010

REVISIONS		TOWN OF BATAVIA
DATE	COMMENTS	HIGHWAY & STORM SEWER DETAILS
		STONE CURB
		DRAWING HS-10