



- NOTES:**
1. ALL BRICK MASONRY UNITS SHALL BE ASTM DESIGNATION C-32 GRADE SS.
 2. MANHOLES WITH OUTLET PIPES 12" DIA. AND LARGER SHALL BE 5'-0" DIA. MANHOLES WITH OUTLET PIPES LESS THAN 12" DIA. SHALL BE 4'-0" DIA.

CAST-IN-PLACE SANITARY SEWER MANHOLE DEPTHS BETWEEN 5'-3" AND 9'-0"

MARCH 2010 N.T.S.

REVISIONS		TOWN OF BATAVIA
DATE	COMMENTS	SANITARY SEWER DETAILS
		CAST-IN-PLACE SANITARY SEWER MANHOLE DEPTHS 5'-3" TO 9'-0"
		DRAWING S-02