

WATER LINE—SEWER LINE CROSSING PROVISIONS

<u>SITUATION</u>	<u>SCHEMATIC</u>	<u>REQUIREMENTS</u>
I WATER LINE ABOVE SEWER LINE		
II WATER LINE ABOVE SEWER LINE		A) WATER LINE AND SEWER LINE SHALL BE ONE FULL LENGTH CENTERED AT CROSSING, WHEN POSSIBLE. B) WHEN BOTH WATER LINE AND SEWER LINE ARE NEW, SLEEVE SEWER LINE WITH STEEL CASING FOR FULL LENGTH OF PIPE AT CROSSING. --OR-- WHEN ONE LINE IS EXISTING, SLEEVE PIPE BEING INSTALLED WITH STEEL CASING FOR ONE FULL LENGTH OF PIPE.
III SEWER LINE ABOVE WATER LINE		A) WATER LINE AND SEWER LINE SHALL BE ONE FULL LENGTH CENTERED AT CROSSING, WHEN POSSIBLE. B) SLEEVE SEWER LINE WITH STEEL CASING FOR ENTIRE LENGTH OF PIPE (EACH SIDE OF CROSSING). C) PROVIDE CRADLE OF CONCRETE OR CRUSHER RUN STONE (SEE TRENCH SECTION DETAIL THIS SHEET) FOR WATER LINE AND SEWER LINE FOR ENTIRE LENGTH OF PIPE EACH SIDE OF CROSSING.

SANITARY SEWER / WATER MAIN CROSSING DETAIL

N.T.S.

MARCH 2010

REVISIONS		TOWN OF BATAVIA
DATE	COMMENTS	SANITARY SEWER DETAILS
		<h3 style="margin: 0;">SANITARY SEWER/ WATER MAIN CROSSING DETAIL</h3>
		DRAWING S-07