



**NOTES:**

- 1) STAINLESS STEEL SERVICE SADDLES SHALL BE USED ON ALL TAPS, SMITH BLAIR.
- 2) STAINLESS STEEL INSERTS SHALL BE USED AT ALL PE CONNECTIONS, MODEL MUELLER-55.
- 3) THE WATER MAIN AT THE LOCATION OF MANUAL AIR RELEASE SHALL BE 6' BELOW GRADE.
- 4) ALL PARTS ARE APPROVED EQUAL.

STAINLESS STEEL SERVICE SADDLE, SMITH BLAIR 372

# MANUAL AIR RELEASE

N.T.S.

MARCH 2010

REVISIONS		TOWN OF BATAVIA
DATE	COMMENTS	WATER DETAILS
		MANUAL AIR RELEASE
		DRAWING W-01