



NOTES:

- 1) THE VALVE BOX SHALL BE BACKFILLED SO THAT IT DOES NOT REST ON THE VALVE HOUSING.
- 2) ALL BOLTS AND NUTS SHALL BE FLUOROCARBON COATED.
- 3) VALVE SHALL BE WRAPPED WITH 2 MIL. THICK POLYETHYLENE 2' BEYOND END OF VALVE.

## GATE VALVE DETAIL

N.T.S.

MARCH 2010

REVISIONS		TOWN OF BATAVIA
DATE	COMMENTS	WATER DETAILS
		GATE VALVE DETAIL
		DRAWING W-04