



# TOWN OF BATAVIA NEW WATER SERVICE CUSTOMER PORTION DETAIL

N.T.S.

**NOTES:**

- 1) STAINLESS STEEL INSERTS SHALL BE USED AT ALL HDPE CONNECTIONS, MODEL FORD INSERT-52.
- 2) HDPE SERVICE LINE SHALL BE ENCLOSED WITH A SLEEVE PIPE COVER OR FINE SAND BEDDING.
- 3) A 10-GAUGE TRACING WIRE SHALL BE MADE CONTINUOUS FROM THE METER PIT TO THE BASEMENT OR CRAWL SPACE. CUSTOMER TO CONNECT TO TRACING WIRE AT THE POINT OF CONNECTION NEAR THE METER PIT.
- 4) THE INTERNAL PLUMBING SYSTEM SHALL BE PROTECTED FROM PRESSURE SURGES, THERMAL EXPANSION, HYDRAULIC SHOCK AND FREEZING PER THE NEW YORK STATE PLUMBING CODE AND BUILDING CODE OF THE TOWN OF BATAVIA.
- 5) MAINTENANCE OF THE WATER SERVICE FROM THE METER PIT TO AND INCLUDING THE INTERNAL PLUMBING ON PREMISES, AND ITS USE, MUST ALWAYS BE KEPT IN FULL COMPLIANCE. THE FOREGOING REMAINS THE SOLE RESPONSIBILITY OF THE WATER CUSTOMER.
- 6) THE CUSTOMER MUST SUBMIT A COMPLETED WATER CONNECTION APPLICATION, OBTAIN TOWN APPROVAL TO PROCEED AND SCHEDULE INSPECTIONS BY THE TOWN PRIOR TO BACKFILLING OR PLACING THE CUSTOMER PORTION INTO USE.
- 7) A LARGER DIAMETER SERVICE LINE MAY BE REQUIRED WHERE DISTANCE, MAIN PRESSURE OR CONSUMER DEMAND ARE A FACTOR.

MARCH 2010

REVISIONS	
DATE	COMMENTS

TOWN OF BATAVIA
WATER DETAILS
TOWN OF BATAVIA CUSTOMER WATER SERVICE DETAIL
DRAWING W-16