

MARCH 2010

REVISIONS

DATE COMMENTS

DATE	COMMENTS


TOWN OF BATAVIA

WATER DETAILS

ROAD/DRIVEWAY TRENCH DETAIL

DRAWING W-17

NEW 1-1/2" ASPHALT CONCRETE TOP COURSE,
NYSDOT SECT 403-2, TYPE 7F2
NEW 2" ASPHALT CONCRETE BINDER COURSE,
NYSDOT SECT 403-2, TYPE 3



NEW 8" GRAVEL SUBBASE COURSE,
NYSDOT SECT. 304-2.02, TYPE 2

LOCAL ROAD AND SHOULDER SECTION

NEW 1" ASPHALT CONCRETE TOP COURSE,
NYSDOT SECT 403-2, TYPE 7F2
NEW 2" ASPHALT CONCRETE BINDER COURSE,
NYSDOT SECT 403-2, TYPE 3



NEW 6" GRAVEL SUBBASE COURSE,
NYSDOT SECT. 304-2, TYPE 2

ASPHALT PARKING LOT/DRIVEWAY SECTION

CALCIUM CHLORIDE-0.5 LBS./S.Y.



NEW 6" GRAVEL SUBBASE COURSE,
NYSDOT SECT. 304-2, TYPE 2


GRAVEL DRIVEWAY/PARKING AREA SECTION

NEW 1-1/2" ASPHALT CONCRETE BINDER
COURSE, NYSDOT SECT 403-2, TYPE 3



NEW 6" GRAVEL SUBBASE COURSE,
NYSDOT SECT. 304-2, TYPE 2

TEMPORARY PAVEMENT REPAIR



GRAVEL SHOULDER SECTION

NOTES:

- EXISTING ROAD, SHOULDER, AND DRIVEWAY SECTIONS WHICH ARE DISTURBED SHALL BE REPLACED IN KIND USING THE VARIOUS TYPICAL SECTIONS AS SHOWN OR ORDERED BY THE ENGINEER.
- ALL SEAMS BETWEEN EXISTING AND NEW ASPHALT SURFACES SHALL BE PRIMED AND SEALED WITH ASPHALT FILLER CORRESPONDING TO THE MATERIAL REQUIREMENTS OF NYSDOT MATERIAL DESIGNATION 702-05 OR 702-3401. THE COST TO BE INCLUDED IN THE VARIOUS WATER MAIN ITEMS.

ROAD, SHOULDER, AND DRIVEWAY TRENCH DETAILS

N.T.S.