



NOTES:

1. ONE STANDARD FULL LENGTH OF WATER MAIN (10 FEET MINIMUM) SHALL BE CENTERED UNDER THE SEWER SO THAT BOTH JOINTS WILL BE AS FAR FROM THE SEWER AS POSSIBLE.
2. THRUST RESTRAINT SHALL BE PROVIDED AT ALL BENDS AND SHALL BE AS INDICATED ON THE DRAWINGS.
3. THERE SHALL BE 1'-6" MINIMUM VERTICAL SEPARATION BETWEEN SEWER AND WATER MAINS.
4. WHERE THE WATER MAIN PASSES UNDER THE SEWER THERE SHALL BE A 6" X 3' MINIMUM OF CONCRETE BEDDING FOR THE SEWER PIPE.
5. SEWER LINE CROSSING SPECIFICS MUST ALSO BE OBSERVED WHEN CROSSING GAS LINES.

SEWER PIPE / WATER MAIN CROSSING DETAIL N.T.S.

MARCH 2010

REVISIONS		TOWN OF BATAVIA WATER DETAILS
DATE	COMMENTS	
		SEWER PIPE CROSSING
DRAWING W-21		