



**NOTES:**

1. CONVENTIONALLY FORMED CONCRETE SIDEWALK SHALL BE 3500 PSI, NYSDOT CLASS A, AIR ENTRAINED CONCRETE. MACHINE FORMED CONCRETE SIDEWALK SHALL BE 3500 PSI, NYSDOT CLASS C, AIR ENTRAINED CONCRETE (NYSDOT ITEM 608.0101).
2. FULL DEPTH EXPANSION JOINTS SHALL BE PROVIDED EVERY 25 FEET. DUMMY OR MARKED JOINTS SHALL BE 5' SPACING.
3. USE WWF6x6 - W6xW6 STEEL MESH AT ALL DRIVEWAY CROSSINGS.
4. TO FACILITATE THE MOVEMENT OF HANDICAPPED PERSONS, NEW SIDEWALK CONSTRUCTION SHALL INCLUDE PROVISIONS FOR RAMPS AT STREET INTERSECTIONS.
5. SEE TYPICAL ROAD SECTION FOR HORIZONTAL AND VERTICAL ALIGNMENT.
6. USE "ACCUSEAL" AS MANUFACTURED BY ALLERTON CHEMICAL COMPANY, "POLYCLEAR" AS MANUFACTURED BY THE UPCO COMPANY, OR APPROVED EQUAL.

## SIDEWALK SECTION

N.T.S.

ISSUE DATE: AUGUST 2012

REVISIONS		TOWN OF BATAVIA
DATE	COMMENTS	HIGHWAY & STORM SEWER DETAILS
		SIDEWALK SECTION
		DRAWING HS-06