



WATER SERVICE DETAIL: CUSTOMER PORTION

N.T.S.

NOTES:

- 1) STAINLESS STEEL INSERTS SHALL BE USED AT ALL HDPE CONNECTIONS.
- 2) HDPE SERVICE LINE SHALL BE ENCLOSED WITH A SLEEVE PIPE COVER OR FINE SAND BEDDING.
- 3) TRACER WIRE SHALL BE MADE CONTINUOUS FROM THE METER PIT TO THE BASEMENT OR CRAWL SPACE. CUSTOMER TO CONNECT TO TRACER WIRE AT THE POINT OF CONNECTION NEAR THE METER PIT.
- 4) THE INTERNAL PLUMBING SYSTEM SHALL BE PROTECTED FROM PRESSURE SURGES, THERMAL EXPANSION, HYDRAULIC SHOCK AND FREEZING PER THE NEW YORK STATE PLUMBING CODE AND BUILDING CODE OF THE TOWN OF BATAVIA.
- 5) MAINTENANCE OF THE WATER SERVICE FROM THE METER PIT TO AND INCLUDING THE INTERNAL PLUMBING ON PREMISES, AND ITS USE, MUST ALWAYS BE KEPT IN FULL COMPLIANCE. THE FOREGOING REMAINS THE SOLE RESPONSIBILITY OF THE WATER CUSTOMER. THE TOWN'S RESPONSIBILITY ENDS AT THE RIGHT-OF-WAY LINE OR EASEMENT AFTER CONSTRUCTION.
- 6) THE CUSTOMER MUST SUBMIT A COMPLETED WATER CONNECTION APPLICATION, OBTAIN TOWN APPROVAL TO PROCEED AND SCHEDULE INSPECTIONS BY THE TOWN PRIOR TO BACKFILLING OR PLACING THE CUSTOMER PORTION INTO USE.
- 7) A LARGER DIAMETER SERVICE LINE MAY BE REQUIRED WHERE DISTANCE, MAIN PRESSURE OR CONSUMER DEMAND ARE A FACTOR. IN SUCH CASES, CONTACT THE TOWN OF BATAVIA.
- 8) PROVIDE SUFFICIENT SLACK IN SERVICE PIPING TO ALLOW FOR EXPANSION AND CONTRACTION OF THE HDPE PIPE.
- 9) PRESSURE GAUGE TO BE INSTALLED ON THE DOWNSTREAM SIDE OF THE PRESSURE REGULATING VALVE.

ISSUE DATE: JUNE 2015

| REVISIONS | DATE | COMMENTS |
|-----------|---------|----------------------|
| | | 07/2021 |
| | 03/2022 | ADDED PRESSURE GAUGE |
| | | |
| | | |

TOWN OF BATAVIA

WATER DETAILS

WATER SERVICE DETAIL: CUSTOMER PORTION

DRAWING W-04C